LEAK CHECK OF VATTERFLY VALVES GPB ENGINEERING PROCEDURE

P0744 Rev-

August 23, 2000

TABLE OF CONTENTS

1.	SCOPE
2.	TEST INFORMATION
2.2	Cleanliness
2.3	ESD precautions
2.4	Personnel, QA, and Documentation
2.5	Red-line Authority4
3.	DOCUMENTS AND EQUIPMENT
3.1	Applicable Documents
3.2	Test Equipment5
3.3	Flight Parts5
4	LEAK TEST OF 2.5" (#3179) VALVES6
4.1	Experiment Setup
5	PROCEDURE COMPLETION9
6.	DATA BASE ENTRY9

1. SCOPE

This procedure describes the leak test of the 2.5 inch and 6" Vatterfly valves. The leak test will run for 60 minutes.

2. TEST INFORMATION

- Proper care should be taken in handling the valves. Cleanliness must be preserved. Do not disturb the motorized mechanism or the sealing plate.
- Temperature: 15-30 ° C
- Humidity: not critical

2.2 Cleanliness

- 2.2.1 Normal lab environment when valves are capped and bagged
- 2.2.2 Class 1000 Clean room when valves are open to atmosphere (use clean bench)

2.3 ESD precautions

2.3.1 None required.

ONR representative, and QA to be notified prior to beginning this procedure				
SU QA	time & date ONR	time & date		

2.4 Personnel, QA, and Documentation

2.4.1 Personnel Integration and Test Director

2.4.2 <u>The Integration and Test Director (ITD)</u> shall be Ron Singley or an alternate that he shall designate. The ITD has overall responsibility for the implementation of this procedure and shall sign off the completed procedure and relevant sections within it. The Vatterfly Manager shall also sign off the completed "As-Built" procedure.

2.4.3 <u>Integration Engineers and other personnel.</u> All engineers and technicians participating in this procedure shall work under the direction of the ITD who shall determine personnel that are qualified to participate in this procedure. Participants in this procedure are to be A. Halevy, R Stephenson, and Chuck Warren.

2.4.4 <u>The test shall be conducted on a formal basis</u> to approved and released procedures. The QA program office shall be notified of the start of this procedure. A Quality Assurance Representative, designated by D. Ross shall be present during the procedure (if deemed

necessary) and shall review any discrepancies noted and approve their disposition. Upon completion of this procedure, the QA Manager, D. Ross or her designate, shall certify their concurrence that the effort was performed and accomplished in accordance with the prescribed instructions by signing and dating in the designated place(s) in this document. <u>Discrepancies will be recorded in a D-log or as a DR per Quality Plan P0108</u>. If a re-test of any or all of the hardware is necessary, the ITD will determine the appropriate changes in the procedure, with the QA and Integration Manager's approval.

2.5 Red-line Authority

2.5.1 <u>Authority to red-line</u> (make minor changes during execution) this procedure is given solely to the ITD or his designate, or the Vattrfly Manager, and shall be approved by QA. Additionally, approval by the Hardware Manager shall be required, if in the judgment of the ITD or QA Representative, experiment functionality may be affected.

2.6 Test Pass/Fail Criteria

- 2.6.1 Helium leak rates for 2.5" valves must be less than $2*10^{-6}$ sccs after 60 minutes.
- 2.6.2 Helium leak rates for 6" valves must be less than $4*10^{-6}$ sccs after 60 minutes.

3. DOCUMENTS AND EQUIPMENT

3.1 Applicable Documents

Document number	Rev	Description
HFS 3179	В	Valve, Vacuum, 2.5"
HFS 3223	В	Valve, Vacuum, 6"
210125	А	6" Pump Valve Cover
210124	А	6" Pump Valve Cover Seal Side
	A	2.5" Pump Valve Cover
	A	2.5" Pump Valve Cover Seal Side

3.2 Test Equipment

Equipment	Model and Serial Number	Calibration Date	Calibration
Helium Leak Detector			Internal leak
Pressure Gage	PGT-45L-30v/30	N/A	For indication only
Standard Leak			Leak Rate=

3.3 Flight Parts

Description	HFS Model	S/N	Comments
6 in. Vat Valve	3223	0002	Flight Spare
2.5 in. Vat Valve	3179	0001	Flight Spare

4 LEAK TEST OF 2.5" (#3179) AND 6" (#3223) VALVES

Started on: _____

4.1 Experiment Setup

- 4.1.1 QA Representative to attend testing on a spot check basis.
- 4.1.2 Testing will be done at Stanford. Assembly will be done on a class 100 clean bench.
- 4.1.3 Attach the probe side pump valve cover to 2.5" valve using proper o-rings. Verify the close position. GSE covers used for backfill should already be installed on space side of valves. If not, install appropriate covers to the space side of the valve.
- 4.1.4 Attach the probe side of valve to the leak detector port of the manifold and space side of the valve to the Helium/Evacuation port.
- 4.1.5 Evacuate probe side of valve and leak check all plumbing.
- 4.1.6 Evacuate space side of valve and leak check plumbing.
- 4.1.7 Close the manual valve to the space side of the Vatterfly valve.
- 4.1.8 Measure the background leak rate.
- 4.1.9 Inject space side of valve with 1 ATM (absolute) helium.
- 4.1.10 Record leak data in <u>Table 1</u> every 30 sec for the first 5 minutes and every 5 minutes thereafter for 60 minutes.
- 4.1.11 Repeat steps 4.1.3 through 4.1.10 on the 6" valve and record data in Table 1 columns 2.

Vatterfly Valve Leak Rates				
	2.5" Valve S/N: 0001	6" Valve S/N: 0002		
Date:				
t ₀ + (min)	Leak Rate (sccs)	Leak Rate (sccs)		
Background	× 10 ⁻	× 10 ⁻		
0.5	× 10 ⁻	× 10 ⁻		
1.0	× 10 ⁻	× 10 ⁻		
1.5	× 10 ⁻	× 10 ⁻		
2.0	× 10 ⁻	× 10 ⁻		
2.5	× 10 ⁻	× 10 ⁻		
3.0	× 10 ⁻	× 10 ⁻		
3.5	× 10 ⁻	× 10 ⁻		
4.0	× 10 ⁻	× 10 ⁻		
4.5	× 10 ⁻	× 10 ⁻		
5.0	× 10 ⁻	× 10 ⁻		
10.0	× 10 ⁻	× 10 ⁻		
15.0	× 10 ⁻	× 10 ⁻		
20.0	× 10 ⁻	× 10 ⁻		
25.0	$\times 10^{-1}$	× 10 ⁻		
30.0	× 10 ⁻	× 10 ⁻		
35.0	× 10 ⁻	× 10 ⁻		
40.0	× 10 ⁻	× 10 ⁻		
45.0	× 10 ⁻	× 10 ⁻		
50.0	× 10 ⁻	× 10 ⁻		

Table 1.Vatterfly Valve Leak Rates

55.0	× 10 ⁻	× 10 ⁻	
60.0	× 10 ⁻	× 10 ⁻	

5 PROCEDURE COMPLETION

The results obtained in the performance of this procedure are acceptable:

	Test Engineer	date:
Discrepancies	if any:	
Approved:	Vatterfly REE	date:
Approved:	QA Representative	date:
Approved:	QA Manager	date:

6. DATA BASE ENTRY

The following data shall be entered into the GP-B Data Base:

- Name, number and revision of this procedure
- Date of successful completion of procedure.
- Part numbers and serial numbers of Caging Units and their components